

SUPERIOR TOWNSHIP 2025 **DRINKING WATER QUALITY REPORT**





2025 Drinking Water Quality Report

Dear Superior Township Water Customer,

We are pleased to present our report for the 2025 calendar year regarding the quality of the drinking water provided by the Superior Township Utility Department to our customers in the Township's Geddes Road Urban Sub-Area between Geddes Road, Ridge Road, Clark Road and Leforge Road. This Consumer Confidence Report is required by the Federal and State of Michigan Safe Drinking Water Acts to be published annually and provides information on where your drinking water comes from, furnishes results of water quality testing we performed throughout 2025, and how those test results compare to Federal and State of Michigan standards. As outlined in this year's report, Superior Charter Township's drinking water met the water quality standards.

As a department of Superior Charter Township, decisions and direction regarding the drinking water system are provided by the Township's seven-member Board of Trustees. The Board of Trustees meet on the third Monday of each month at 7:00 pm at the Township Hall located at 3040 North Prospect Road (the corner of Prospect & Cherry Hill). If a holiday occurs on a third Monday, the meeting is held on the Tuesday immediately following the holiday. The current meeting schedule and agendas are available at **Board of Trustees – Superior Township, Washtenaw County** (<https://superiortownship.org/boards-commissions/board-of-trustees>)

Our Utility Department staff, and the staff of the Great Lakes Water Authority (GLWA) where your water comes from, take great pride in our hard work and diligence to provide you, our customers, the safe, reliable, and exceptional drinking water you expect and deserve. We appreciate you taking the time to review this report and your interest in our water system. If you have any questions, need additional information about Superior Township's water system, or would like to receive a hard copy of this water quality report, please contact us at utilitydept@superior-twp.org or **734-480-5500**.

Sincerely,

Mary Burton
Utility Director

Table of Contents

- 1 Information About GLWA
- 1 Cryptosporidium and Giardia
- 1 Source Water Assessment
- 2 Minimizing Lead Exposure
- 2 Lead and Copper Facts
- 3 Health and Safety Information
- 3-5 Superior Township Water Quality Test Results for 2025
- 4 Definitions
- 5 Additional Information: 2025 GLWA Tap Water Mineral Analysis



Information About GLWA

Superior Township obtains your drinking water from the Great Lakes Water Authority (GLWA) water system. Your source water comes from the Detroit River, situated within the Lake St. Clair, Clinton River, Detroit River, Rouge River, and Ecorse River watersheds in the U.S. and parts of the Thames River, Little River, Turkey Creek, and Sydenham watersheds in Canada.

Drinking water quality is important to our community and the region. Superior Township and GLWA are committed to meeting state and federal water quality standards including the Lead and Copper Rule. With the Great Lakes as our water source and proven treatment technologies, the GLWA consistently delivers safe drinking water to our community. Superior Township operates the system of water mains that carry this water to your home's service line. This year's Water Quality Report highlights the performance of GLWA and Superior Township water professionals in delivering some of the nation's best drinking water. Together, we remain committed to protecting public health and maintaining open communication with the public about our drinking water. If you wish to learn more about the plants that treat our water or obtain information regarding GLWA Board meetings, please visit www.glwawater.org.

Cryptosporidium and Giardia

GLWA voluntarily monitors for Cryptosporidium and Giardia in our source water monthly. The untreated water samples collected from our Belle Isle Intake indicated the presence of one Giardia cyst in February 2025. All other samples collected from the Belle Isle Intake and Fighting Island Intake in 2025 were absent for the presence of Cryptosporidium and Giardia. Systems using surface water like GLWA must provide treatment so that 99.9% of Giardia lamblia and Cryptosporidium is removed or inactivated. GLWA's drinking water treatment process is designed to remove and inactivate these protozoans.

Source Water Assessment

Michigan's Department of Environment, Great Lakes, and Energy (EGLE), in partnership with the U.S. Geological Survey, the Detroit Water and Sewerage Department, and the Michigan Public Health Institute, performed a source water assessment in 2004 to determine the susceptibility of GLWA's Detroit River source water for potential contamination. The susceptibility rating is based on a seven-tiered scale and ranges from very low to very high, determined primarily using geologic sensitivity, water chemistry, and potential contaminant sources. The report described GLWA's Detroit River intakes as highly susceptible to potential contamination. GLWA's Southwest and Springwells water treatment plants that draw water from the Detroit River have historically provided satisfactory treatment and meet drinking water standards.

GLWA has initiated source-water protection activities that include chemical containment, spill response, and a mercury reduction program. GLWA participates in the National Pollutant Discharge Elimination System permit program and has an emergency response management plan. GLWA has Surface Water Intake Protection Plans for the Belle Isle Intake and the Fighting Island Intake. The plan has seven elements that include: roles and duties of government units and water supply agencies, delineation of source water protection areas, identification of potential sources of contamination, management approaches for protection, contingency plans, siting of new water sources, public participation, and public education activities. If you would like to know more information about the Source Water Assessment report, please contact GLWA at 313.926.8127.

GLWA is required to notify water users of any unresolved significant deficiencies identified by EGLE. Below is the status of significant deficiencies in the GLWA water system identified by EGLE:

Date Identified by EGLE	Description	Compliance Agreement Deadline	Status
08-02-2022	Improper rapid mixing and coagulant feed location at the Southwest water plant	12-31-2027	Coagulant feed was completed 12/11/2024. Rapid mix is in the design phase. <i>On track to meet the deadline.</i>
08-02-2022	Inoperable flocculation equipment at the Southwest water plant	07-31-2031	A contractor for the design portion of the project will be awarded shortly. <i>On track to meet the deadline.</i>
05-25-2022	Inoperable rapid mixing equipment at the Springwells 1930s water plant	12-31-2023	Completed in December 2023
05-25-2022	Inoperable flocculation equipment at the 1958 Springwells water plant	11-11-2027	Phase I construction is completed as of December 2024. Phase II is under construction. <i>On track to meet the deadline.</i>



Minimizing Lead Exposure

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Superior Township is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry, or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water, you may wish to have your water tested, by contacting Superior Township at 734.480.5500 for available resources. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead/>.



If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water, you may wish to have your water tested, by contacting Superior Township at 734.480.5500 for available resources. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead/>.

Lead and Copper Facts

Safe drinking water is a shared responsibility. The water that GLWA delivers to our community does not contain lead. Lead can leach into drinking water through home plumbing fixtures, and in some cases, customer service lines. Corrosion control reduces the risk of lead and copper from leaching into your water. Orthophosphates are added during the treatment process as a corrosion control method to create a protective coating in service pipes throughout the system, including in your home or business. Superior Township performs required lead and copper sampling and testing in our community. Water consumers also have a responsibility to maintain the plumbing in their homes and businesses and can take steps to limit their exposure to lead.

Infants and children who drink water containing lead could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

As of 2019, the Safe Drinking Water Act requires water utilities to inventory the service lines in its service area. Superior Township contains 2,678 service lines. There are no lead service lines and no service lines of unknown material in Superior Township.



Additional Actions Homeowners Can Take to Reduce Lead Exposure from Tap Water

- Prior to drinking, let water run until it feels cold.
- Only use cold water for drinking, cooking, and making baby formula, as it is less likely to contain lead than hot tap water.
- Remove aerators in faucets and clean them every six months, at a minimum.
- Replace faucets, fittings, and valves sold before 2014, as they may contain up to 8 percent lead, even if marked lead-free.



Health and Safety Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by emailing the U.S. Environmental Protection Agency's (EPA) Safe Drinking Water Hotline at safewater@epa.gov.

More Resources

EPA Safe Drinking Water Hotline: safewater@epa.gov
Website: www.epa.gov/ground-water-and-drinking-water
Michigan Department of EGLE Website: www.michigan.gov/egle

The sources of drinking water (tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it can dissolve naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organics, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in the water provided by public water systems. The Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Based on testing results during 2025 (Test Results Table), contaminants were below the level of concern for safe drinking water standards set by EPA and EGLE.



Superior Township Water Quality Test Results for 2025

GLWA and Superior Township collect water samples above and beyond Federal and State requirements. Drinking water may contain small amounts of some parameters. This does not indicate a health risk. The tables below summarize the detectable results, public health goals, the highest concentration allowed, and likely sources. This table does not show the hundreds of other contaminants tested for, but not found in your drinking water. The test results confirm that ALL DETECTED CONTAMINANTS WERE BELOW REGULATED LEVELS. THERE WERE NO VIOLATIONS OF FEDERAL OR STATE DRINKING WATER STANDARDS.

Definitions

< - Symbol for less than.

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other required actions a water system must follow.

Celsius (°C) - A scale of temperature in which water freezes at 0° and boils at 100° under standard conditions.

Haloacetic Acids (HAA5) - The total of bromoacetic, chloroacetic, dibromoacetic, dichloroacetic, and trichloroacetic acids. Compliance is based on the total.

Maximum Contaminant Level (MCL) - The highest level of a contaminant allowed in drinking water. MCLs are set as close to the MCLGs as feasible, using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs provide a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - Level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

micromhos (µmhos) - Measure of electrical conductance of water.

na - Not applicable.

Not Detected (ND) - The analytical result for the pollutant was below the reporting level used by the laboratory performing the analysis.

Nephelometric Turbidity Unit (NTU) - Measures the cloudiness of water.

Parts per trillion (ppt) (one in one trillion) - Equivalent to nanograms per liter. A nanogram = 1/1,000 microgram = 1/1,000,000 milligram

Parts per billion (ppb) (one in one billion) - Equivalent to micrograms per liter. A microgram = 1/1,000 milligram.

Parts per million (ppm) (one in one million) - Equivalent to milligrams per liter. A milligram = 1/1,000 gram.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Total Trihalomethanes (TTHMs) - The sum of chloroform, bromodichloromethane, dibromochloromethane and bromoform. Compliance is based on the total.

Regulated Inorganic Parameters (annual monitoring at plant finished water taps)

Contaminant	Test Date	Unit	Level Detected	MCLG	MCL	Likely Sources
Fluoride	2025	ppm	0.50	4	4	Water additive to promote strong teeth, erosion of natural deposits, discharge from fertilizer and aluminum factories
Nitrate	2025	ppm	0.35	10	10	Fertilizer runoff, leaching from septic tanks, sewage, erosion of natural deposits

Regulated Disinfectant Residuals and Disinfection By-Products (sampled in the distribution system)

Contaminant	Test Date	Unit	Result	Low	High	MCLG	MCL	Likely Sources
TTHMs	2025	ppb	57	n/a	n/a	n/a	80	By-products of drinking water disinfection

Haloacetic Acids 2025 ppb 17 n/a n/a n/a 60 By-products of drinking water disinfection

Samples were collected to test for the disinfection by-products TTHMs and Haloacetic Acids in Superior Township at the frequencies and times prescribed by Federal regulations. The samples collected throughout Superior Township distribution system during 2025 met the MCL for disinfection by-products.

Contaminant	Test Date	Unit	Result	Low	High	MCLG	MCL	Likely Sources
Disinfectant Chlorine	2025	ppm	0.88	0.59	0.95	4	4	Water additive used to control microbes

Regulated Microbiological Parameters

Contaminant	Test Date	Unit	Highest Result	MCLG	MCL	Likely Sources
Total Coliform	2025	--	0	0	>1 positive sample/month	Naturally present in the environment
E. Coli	2025	--	0	0	>1 positive sample/month	Human or animal fecal waste
Turbidity	2025	NTU	0.21	0	1.0	Soil runoff

Turbidity is a measure of the cloudiness of water. Turbidity is monitored every 4 hours at the plant taps. We monitor it because it is a good indicator of the effectiveness of our filtration system. The rules state that turbidity must never exceed 1.0 NTU (see "highest result") and must not exceed 0.3 NTU in more than 95% of daily samples in any single month. The turbidity in daily samples was below 0.3 NTU 100% of the time.

Copper and Lead Testing (sampled at individual taps)

Contaminant	Test Date	Unit	90th	Samples >AL	Range of Individual Results	MCLG	MCL	Likely Sources
Lead	2025	ppb	0	0	0 ppb - 0 ppb	0	AL=12	Lead services lines, corrosion of household plumbing including fittings and fixtures, erosion of natural deposits
Copper	2025	ppm	0.1	0	0.0 ppm - 0.1 ppm	1.3	AL=1.3	Corrosion of household plumbing systems, erosion of natural deposits; leaching from wood preservatives

Lead and Copper compliance is based on the 90th percentile, where nine out of ten samples must be below the Action Level (AL). If the 90th percentile value is above the AL, additional requirements must be met.

Regulated Organic Contaminant

Contaminant	Test Date	Unit	Highest result	Range of Individual Results	MCL	Likely Sources
Perfluorooctanoic acid (PFOA)	2025	ppt	2	ND - 2 ppt	8	Industrial manufacturing sites, fire-fighting foams (AFFF) used at airports/military bases, and waste management facilities like landfills.



Total Organic Carbon (TOC) Removal

The TOC removal ratio is calculated as the ratio between the actual TOC removal and the TOC removal requirements. During 2025, TOC was measured each quarter and because the level was low, there is no TOC removal requirement.

UNREGULATED PARAMETERS (No established EPA drinking water standards)

Contaminant	Test Date	Unit	Level Found	EPA Health Guidance	Likely Sources
Sodium	2025	ppm	6.8	20	Erosion of natural deposits

6.8 ppm equates to about 1.61 milligrams of sodium per 8-ounce glass of water. EPA Health Guidance is for people restricted to taking in less than 500 mg of sodium per day according to "Drinking Water Advisory: Consumer Acceptability Advice and Health Effects Analysis on Sodium," US EPA, EPA 822-R-03-006, February 2003.

Unregulated Contaminant Monitoring Rule (sampled in the distribution system)

Unregulated contaminants are those for which EPA has not established drinking water standards. Monitoring helps EPA to determine where these contaminants occur and whether it needs to regulate those contaminants.

Note: Fifth Unregulated Contaminant Monitoring Rule sampling was conducted on March 10, 2025; June 11, 2025; September 15, 2025; and December 9, 2025. The samples were analyzed for 29 Per- and polyfluoroalkyl substances (PFAS) compounds and the metal lithium. The results for the PFAS compounds and lithium were all below the minimum reporting limits.

Additional Information: 2025 GLWA Tap Water Mineral Analysis

Parameter	Units	Average	Low	High
Turbidity	NTU	0.07	0.02	0.16
Total Solids	ppm	132	41	172
Total Dissolved Solids	ppm	118	69	158
Aluminum	ppm	0.048	0.013	0.122
Iron	ppm	0.2	ND	0.3
Copper	ppm	0.002	ND	0.034
Magnesium	ppm	7.8	6.9	8.8
Calcium	ppm	27.3	24.3	35.3
Sodium	ppm	3.8	0.4	9.0
Potassium	ppm	1.1	0.9	1.6
Manganese	ppm	ND	ND	ND
Lead	ppm	ND	ND	ND
Zinc	ppm	ND	ND	ND
Silica	ppm	2.0	1.0	3.9
Sulfate	ppm	28.1	21.7	38.5
Chloride	ppm	11.4	9.5	16.4

Parameter	Units	Average	Low	High
Phosphorus	ppm	0.84	0.57	1.07
Free Carbon Dioxide	ppm	10	1.7	15.3
Total Hardness	ppm	108	96	142
Total Alkalinity	ppm	70	62	76
Carbonate Alkalinity	ppm	ND	ND	ND
Bi-Carbonate Alkalinity	ppm	70	ND	76
Non-Carbonate Hardness	ppm	37	27	72
Chemical Oxygen Demand	ppm	3.6	ND	22.6
Dissolved Oxygen	ppm	11.3	7	19.3
Nitrite Nitrogen	ppm	ND	ND	ND
Nitrate Nitrogen	ppm	0.37	ND	1.15
Fluoride	ppm	0.58	ND	0.78
pH	s.u.	7.16	6.96	7.92
Specific Conductance @ 25 °C	µmhos	220	135	258
Temperature	°C	12.9	1.4	26.1

s.u. - Specific units